

Clarification		
Ref. No: SECI/SD/NIT/2016/BDL/5MW/CLR-02		Date: 01/08/2016
Clause	Page No.	Clarification
11.1	89 & 90 of 122	It is hereby clarified that “any shortfall in radiation” is not be considered in the calculation of CUF, however to meet CUF requirement contractor may install additional PV modules.