

Amendment - 4

RfB No: SECI/C&P/RfB/2018/160MWH/WB/01

RfB for Design, Engineering, Supply, Construction, Erection, Testing & Commissioning of 160 MW Solar-Wind Hybrid Power Plant with BESS including 10 Years Plant O&M under International competitive bidding at Ramagiri, Anantapur district, Andhra Pradesh, India

Sl. No.	Section	Page No.	Clause	Original Version	Amendment
1	Employers Requirement Annexure A, Part II	361	23.1.3	The Offered WTG model should be listed in the Revised List of Models and Manufacturers (RLMM list) of MNRE as on the date of bid submission should be offered. Any WTG model not listed in RLMM as on the date of last date of bid submission shall not be considered for evaluation.	The Offered WTG model should be listed in the Revised List of Models and Manufacturers (RLMM) list of MNRE as on the date of commissioning. This revised clause related to RLMM registration timelines will supersede any other clause related to RLMM registration timelines mentioned anywhere in the Bidding document.
2	Employers Requirement Annexure A, Part IV	579	8.6	Contractor shall prepare and send Forecasting and Scheduling generation reports as per extant regulations (SERC/CERC) for Forecasting, Scheduling, Deviation Settlement Mechanism and related matters. The scope under this Clause shall also include establishing and maintaining forecasting tools and appointment of QCA/Aggregator, if required. % Error (Deviation) shall be calculated as per the said regulations and DSM Charges in case of deviation beyond the permissible limits shall be borne by the Contractor.	Contractor shall prepare and send Forecasting and Scheduling generation reports as per extant regulations (SERC/CERC) for Forecasting, Scheduling, Deviation Settlement Mechanism and related matters with the approval of SECI. However, DSM Penalty charges levied on SECI under the said regulation shall be borne by the Contractor, to the maximum extent of 10% of the Annual O&M charges of the respective year quoted by the Contractor in its Bid.